



## **WEST JORDAN FIRE DEPARTMENT - Pre-Fire Inspection Checklist**

7602 S. Jordan Landing Blvd, West Jordan, UT. 84084

Office (801) 260-7300 Fax (801) 260-7321

### **ADDRESS**

Address identification must be properly posted on street side of the building (4" tall - visible from street).	IFC2015 505.1
--	---------------

### **ELECTRICAL**

Electrical panels are accessible (min. 30" width, 78" height, 36" in depth).	IFC2015 605.3
UL approved electrical multi-plug adapters (circuit breaker type power strips) can be used if plugged directly into the outlet. "Piggy-backing" of power strips is not allowed.	IFC2015 605.4.1
	IFC2015 605.4.2
Extension cords are for temporary use only and not used through walls, ceilings, or under doors.	IFC2015 605.5
All outlets, switches, open-wiring splices, etc. are prohibited and need to be covered.	IFC2015 605.6
Electrical panels need to be properly covered and latched.	IFC2015 605.6

### **EXITS**

No storage under unprotected exit stairways	IFC2015 315.3.4
Exit doors unlocked during business hours.	IFC2015 1010.1.9.3
Exit signs where required.	IFC2015 1013.1
Lighted exit signs operating properly.	IFC2015 1013.6.3
Exit ways clear from obstructions.	IFC2015 1031.2

### **EXTINGUISHERS**

Wet chemical suppression systems (kitchen hoods, etc.) inspected every 6 months	IFC2015 904.5
Dry chemical suppression systems (paint & spray booths, etc.) inspected every 6 months	IFC2015 904.6
Extinguisher has a current State Fire Marshal inspection tag.	IFC2015 906.2
Minimum size: 2A:10BC (5 lbs.) extinguisher.	IFC2015 906.3
Correct number and type for occupancy (maximum distance of travel to extinguisher - 75 feet).	IFC2015 906.3.1
Extinguishers - Properly mounted and accessible (no higher than 5', no less than 4" from floor).	IFC2015 906.9

### **HOUSEKEEPING**

Dispose of combustible waste (boxes, papers, debris, etc.).	IFC2015 304.1
Exterior free of trash and weeds.	IFC2015 304.1.2
Oily rags stored in approved containers.	IFC2015 304.3.1
All ceiling tiles in place and intact (no holes, missing tiles, etc.).	IFC2015 703.1

### **MECHANICAL**

No combustibles stored in furnace, boiler, or sprinkler riser room.	IFC2015 315.3.3
Furnace, boiler, water heater, etc., vented to prevent a fire hazard.	IFC2015 603.6
Gas meter is accessible and protected by a barrier to prevent damage.	IFC2015 603.9

### **SMOKING**

Smoking of any type prohibited in warehouse storage areas and/or other hazardous areas	IFC2015 310.2
--	---------------

### **STORAGE**

Storage maintained 24" below ceiling (non-sprinklered building), 18" below (sprinklered building)	IFC2015 315.3.1
No combustible storage in unprotected attics or crawl spaces.	IFC2015 315.3.4
Compressed gas cylinders secured from falling.	IFC2015 5303.5.3
All flammable and combustible liquids are stored properly.	IFC2015 5704.3
Accumulated flammable and combustible liquids do not exceed allowable quantities.	IFC2015 5705.3.5.2

### **ALARM AND SPRINKLER SYSTEMS (if applicable)**

Sprinkler riser room and fire alarm panel readily accessible.	IFC2015 509.2
Fire alarm sprinkler system inspected and tagged annually.	IFC2015 901.6.1
Fire and life safety systems are maintained in an operable condition.	IFC2015 901.6.1